

# ***CO2 Capture Project***

## **Post Combustion CO<sub>2</sub> Removal Cost Efficient Design & Integration Study**

**Robert Chu  
Nexant, Inc.**

**Funded by the CO2 Capture Project and the Research Council of Norway**

**October 14/15, 2003**

This presentation was prepared with the support of the Research Council of Norway/Klimatek under Awaard No. 144737/228. Any opinions, findings, conclusions or recommendations expressed herein are those of the author(s) and do not necessarily reflect the views of the Klimatek.

**[www.co2captureproject.org](http://www.co2captureproject.org)**

# *NGCC Post Combustion CO<sub>2</sub> Removal “Cost Efficient Design & Integration Study”*

*Statoil Contract No. 4500478718*

CCP Manager

Daniel Chinn

ChevronTexaco

Principal Authors

Robert Chu

Nexant Inc.

Gerald N. Choi

Nexant Inc.

Bruce D. Degen

Bechtel

# *Presentation Outline*

- *Objective*
- *Design Criteria & Design Basis*
- *Study Methodology*
- *Base Case Add-on Amine Plant Design*
- *Cost Cutting Ideas Generation & Trade-off Evaluation*
- *Alternate Low Cost Add-on Amine Plant Design*
- *Add-on Amine Plant Capital Cost & Utility Demand Comparison*
- *Low Cost Alternate Design Uncertainties*
- *Integrated NGCC/Low Cost Alt Amine scheme selection & design*
- *Integrated Scheme Capital Cost & Utility Demand Comparison*
- *Integrated Design Uncertainties*
- *Conclusions*

# *Study Objective and CO<sub>2</sub> Removal Plant Boundary Defined*

## CCP Objective:

- Identify alternate designs to reduce Capital and Operating Cost of CO<sub>2</sub> Removal from NGCC flue gas.

## CO<sub>2</sub> Removal Plant Boundary:

- Flue Gas Feed from HRSG outlet
- CO<sub>2</sub> Product at Compression outlet, exclude pipeline and final disposal facilities.

# *CO<sub>2</sub> Removal Plant as ‘Added-On’ to NGCC Power Plant – Design Criteria*

- Base Case and Low-Cost Alternative CO<sub>2</sub> Removal Plants shall be designed as ‘added-on’ to an existing NGCC power plant.
- Added-on designs are considered near-term options (I.e., can be implemented in 3-to-10 years)
- Base Case shall be designed to meet API and Refining specifications.
- Low-Cost Alternative CO<sub>2</sub> shall be designed assuming non-critical service.

# *CO<sub>2</sub> Removal as an Integrated Plant to a NGCC Power Plant – Design Criteria*

- Integrated NGCC and Low-Cost Alternative CO<sub>2</sub> Removal plant shall be designed to operate as a single plant.
- Integrated designs are considered to be long-term options (over 10 years away). Extensive equipment development efforts will be needed.

# *Design Basis*

- Norwegian Coastal Site.
- CO<sub>2</sub> Product Specifications:
  - 220 barg and 60 °C B/L Pressure and Temp
  - 50 ppmv maximum moisture
- Once-through Seawater Cooling
  - 11 °C supply temperature
  - 22 °C maximum return temperature

# *Study Methodology*


- Brainstorm to generate cost reduction ideas.
- Perform qualitative screening analysis to select ideas for quantitative trade-off analysis.
- Develop Base Case design and cost estimate.
- Perform quantitative trade-off analysis on screened ideas to determine feasibilities.
- Select feasible ideas and develop Alternate Low-Cost design and cost estimate.
- Select integration ideas and develop Integrated NGCC/Low-Cost Plant design and cost estimate.




# *Base Case Amine Plant Design*

- 86% CO<sub>2</sub> removal from 400 MW NGCC flue gas.
- 30 wt% MEA based CO<sub>2</sub> removal process.
- H&M balances and equip sizing from T-Sweet, Amsim, and in-house spreadsheet models.
- Major equipment factored cost estimate. Equip costs are per vendor quotations, ICARUS predictions, and in-house historical data.
- Bechtel's low-cost PowerLine 350 MW CCGT Power Plant, modified for this study with net power output of 385 MW, will serve as the Base Case power plant.


# Base Case Amine Block Flow Diagram



# Base Case Amine Flow Scheme



# Base Case CO<sub>2</sub> Compression Flow Scheme



# *Brainstorm Results*

- Generated 64 ideas.
- Rejected 39 through screening because not feasible, not practical, or redundant.
- 7 to be considered during the Integrated NGCC/CO<sub>2</sub> Removal design.
- Performed 18 trade-off analysis for possible implementation in Low-Cost Alternative scheme.


# *Trade-Off Analysis Results*

- 13 of the 18 ideas evaluated deem un-feasible.
- 5 were selected for implementation in the Low-Cost Alternative scheme:
  - Eliminate flue gas cooling.
  - Depressure hot lean amine with ejector.
  - Use plate & frame exchangers.
  - Use ANSI pumps instead of API pumps.
  - Use structured packing in Absorber.
- Added 6<sup>th</sup> idea: use single train CO<sub>2</sub> Compression.

# *Low-Cost Alternative Design*

- 30 wt% MEA based CO<sub>2</sub> removal process.
- Implemented the 6 recommendations from the trade-off analysis.
- Identical H&M balances and equipment sizing procedures as Base Case.
- Identical cost estimate procedures as Base Case.
- Identical NGCC Power Plant design as Base Case.

# Low Cost Amine Block Flow Diagram




10/10/03

CHU\_Oct\_14\_03\_Rev\_2



# Low Cost Amine Flow Scheme



# *Added-On CO<sub>2</sub> Removal – Utility Demands*

	<u>Base Case</u>	<u>Low-Cost</u>
<u>Utility Demands:</u>		
Steam Import, mT/h	238	201
Power Import, MW	20	19
Condensate Export, m <sup>3</sup> /h	177	147
SW Cooling Duty, 10 <sup>6</sup> KJ/h	623	550
CO <sub>2</sub> Recovered, mT/D	2,850	2,850

# *NGCC Performances*

	<u>Design</u>	<u>Base Case</u>	<u>Low-Cost</u>
Power Export, MW:			
To CO2 Removal	0	20	19
To Grid	385	314	323
Steam Export, mT/h	0	238	201
Condensate Import, m <sup>3</sup> /h	0	177	147
SW Cooling Duty, 10 <sup>6</sup> KJ/h	824	358	432
Nat Gas Burned, MW(LHV)	687	687	687
CO <sub>2</sub> Generated, mT/D	3,314	3,314	3,314

# *Low-Cost Alternative Design – Performance Verification Required*

- Absorption performance without flue gas cooling.
- Structure packing absorption performance.
- Local Codes & Standards requirement on using ANSI pumps instead of API pumps.


# *Integrated Scheme Selection*

- 5 of the 7 integration ideas judged to be infeasible.
- 2 were implemented in the Integrated NGCC/Low-Cost Alternate Design:
  - Recycle portion of the HRSG flue gas to the GT Air Compressor.
  - Insert Amine Reboiler tube bundles directly in the HRSG.

# *Integrated NGCC/Low-Cost Alternative Design*

- 30 wt% MEA based CO<sub>2</sub> removal process.
- Recycled no more than 50% of the HRSG flue gas to maintain minimum 13 vol% O<sub>2</sub> in combustion air mixture.
- Cooled recycle flue gas to 27 °C before return to air compressor.
- NGCC Power Plant HRSG, STG, and surface condenser sizes and costs were reduced to match the smaller power plant loads.

# Integrated Design Block Flow Diagram



# *Integrated Scheme – CO<sub>2</sub> Removal Plant Utility Demands*

	<u>Low-Cost</u>	<u>Integrated Design</u>
<u>CO<sub>2</sub> Removal Utility Demands:</u>		
Steam Import, mT/h	201	77
Power Import, MW	19	19
Condensate Export, m <sup>3</sup> /h	147	32
SW Cooling Duty, 10 <sup>6</sup> KJ/h	550	501
CO <sub>2</sub> Recovered, mT/D	2,850	2,838



# *NGCC Performance*

	<u>Design</u>	<u>Low-Cost</u>	<u>Integrated</u>
Power Export, MW:			
To CO2 Removal	0	19	19
To Grid	385	323	325
Steam Export, mT/h	0	201	77
Condensate Import, m <sup>3</sup> /h	0	147	32
SW Cooling Duty, 10 <sup>6</sup> KJ/h	824	432	621
Nat Gas Burned, MW(LHV)	687	687	684
CO <sub>2</sub> Generated, mT/D	3,314	3,314	3,300

# *Integrated Design – Performance Verification Needed*

- Confirm with Gas Turbine vendors on the feasibility of recycling flue gas back to the air compressor, and of operating the combustor continuously at 13% oxygen.
- Verify with HRSG vendor that the amine reboiler tube skin temperature can be kept below 145 °C to avoid excess amine degradation.
- Verify regulatory and insurance requirement regarding to heat amine solutions in HRSG.

# *Conclusions*

- Add-On MEA-based CO<sub>2</sub> Removal plants capital cost can be reduced by:
  - utilizing P&F exchangers, structure packing, and ANSI pumps.
  - by integrating the NGCC and the CO<sub>2</sub> Removal plants
- Operating cost can be reduced.
- Further reduction in costs would require solvent changes.